

FACT SHEET FOR NPDES PERMIT NO. WA0000353

Clariant Corporation Kalama Plant

FACT SHEET FOR NPDES PERMIT NO. WA0000353

TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION	1
GENERAL INFORMATION	1
BACKGROUND INFORMATION.....	2
DESCRIPTION OF THE FACILITY.....	2
History	2
Industrial Process	2
Discharge Outfall	2
PERMIT STATUS.....	2
SUMMARY OF COMPLIANCE WITH THE PREVIOUS PERMIT.....	2
WASTEWATER CHARACTERIZATION	2
SEPA COMPLIANCE.....	3
PROPOSED PERMIT LIMITATIONS	3
DESIGN CRITERIA	3
TECHNOLOGY-BASED EFFLUENT LIMITATIONS	4
SURFACE WATER QUALITY-BASED EFFLUENT LIMITATIONS.....	4
Numerical Criteria for the Protection of Aquatic Life	4
Numerical Criteria for the Protection of Human Health.....	4
Narrative Criteria	4
Antidegradation	4
Critical Conditions.....	5
Mixing Zones.....	5
Description of the Receiving Water.....	5
Surface Water Quality Criteria	5
Consideration of Surface Water Quality-Based Limits for Numeric Criteria.....	6
Whole Effluent Toxicity	6
Human Health	6
Sediment Quality	6
GROUND WATER QUALITY LIMITATIONS.....	7
COMPARISON OF EFFLUENT LIMITS WITH THE EXISTING PERMIT ISSUED	7
MONITORING REQUIREMENTS	7
LAB ACCREDITATION	7
OTHER PERMIT CONDITIONS	8
REPORTING AND RECORDKEEPING	8
SPILL PLAN	8
GENERAL CONDITIONS.....	8
PERMIT ISSUANCE PROCEDURES	8
PERMIT MODIFICATIONS	8
RECOMMENDATION FOR PERMIT ISSUANCE	9
REFERENCES FOR TEXT AND APPENDICES.....	9

FACT SHEET FOR NPDES PERMIT NO. WA0000353

TABLE OF CONTENTS (cont.)

	<u>Page</u>
APPENDIX A--PUBLIC INVOLVEMENT INFORMATION	10
APPENDIX B--GLOSSARY	11
APPENDIX C--TECHNICAL CALCULATIONS	14
APPENDIX D--RESPONSE TO COMMENTS	15

FACT SHEET FOR NPDES PERMIT NO. WA0000353

INTRODUCTION

The Federal Clean Water Act (FCWA, 1972, and later modifications, 1977, 1981, and 1987) established water quality goals for the navigable (surface) waters of the United States. One of the mechanisms for achieving the goals of the Clean Water Act is the National Pollutant Discharge Elimination System (NPDES) permits which is administered by the Environmental Protection Agency (EPA). The EPA has delegated responsibility to administer the NPDES permit program to the state of Washington on the basis of Chapter 90.48 RCW which defines the Department of Ecology's authority and obligations in administering the wastewater discharge permit program.

The regulations adopted by the state include procedures for issuing permits (Chapter 173-220 WAC), water quality criteria for surface and ground waters (Chapters 173-201A and 200 WAC), and sediment management standards (Chapter 173-204 WAC). These regulations require that a permit be issued before discharge of wastewater to waters of the state is allowed. The regulations also establish the basis for effluent limitations and other requirements which are to be included in the permit. One of the requirements (WAC 173-220-060) for issuing a permit under the NPDES permit program is the preparation of a draft permit and an accompanying fact sheet. Public notice of the availability of the draft permit is required at least thirty days before the permit is issued (WAC 173-220-050). The fact sheet and draft permit are available for review (see Appendix A--Public Involvement of the fact sheet for more detail on the Public Notice procedures).

The fact sheet and draft permit have been reviewed by the Permittee. Errors and omissions identified in this review have been corrected before going to public notice. After the public comment period has closed, the Department of Ecology (the Department) will summarize the substantive comments and the response to each comment. The summary and response to comments will become part of the file on the permit and parties submitting comments will receive a copy of the Department's response. The fact sheet will not be revised. Comments and the resultant changes to the permit will be summarized in Appendix D--Response to Comments.

GENERAL INFORMATION

Applicant:	Hoescht Celanese Kalama Plant	
Facility Name and Address:	P.O. Box 10, 404 Hendrickson Drive Kalama, WA 98625	
Type of Facility:	Inorganic Chemical Process Plant	
SIC Code:	2819	
Discharge Location:	Columbia River Latitude: 45° 59' 48" N Longitude: 122° 50' 35" W.	
Water Body ID Number:	26-01-00	

FACT SHEET FOR NPDES PERMIT NO. WA0000353

BACKGROUND INFORMATION

DESCRIPTION OF THE FACILITY

HISTORY:

This facility has been permitted since 1976. There are no records of the date this facility was constructed. The plant originally treated some waste in lagoons, but these lagoons were closed in 1989. The facility originally produced zinc hydrosulfite and sodium hydrosulfite but the zinc hydrosulfite production has been discontinued. This is an EPA minor permit.

INDUSTRIAL PROCESS

In this process, sulfuric acid and zinc are combined with a small amount of cadmium sulfate to produce a mixture of sodium hydrosulfite and water for use in paper production. A byproduct of the process is zinc oxide which is sold for use as an additive in the rubber industry. The facility also stores a certain amount of dry sodium hydrosulfite manufactured elsewhere for use if the local process cannot meet the demand. The facility operates 7 days a week, 3 shifts, and employs 12 people. All process and stormwater are collected and reused, leaving the plant as product. The only wastewater presently discharged is non-contact cooling water. All chemical storage and the chemical unloading and unloading area are contained so that any spills are caught and disposed of properly. The installation is neat and clean.

DISCHARGE OUTFALL

The outfall is beneath the Columbia River. It is a diffuser with 20 ports.

PERMIT STATUS

The previous permit for this facility was issued on May 20, 1976, and subsequently extended by letter. The previous permit placed effluent limitations on flow, temperature, pH, and zinc.

An application for permit renewal was submitted to the Department on January 2, 1997 and accepted by the Department on April 21, 1997.

SUMMARY OF COMPLIANCE WITH THE PREVIOUS PERMIT

The facility last received an inspection on August 19, 1994.

During the history of the previous permit, the Permittee has remained in compliance based on Discharge Monitoring Reports (DMRs) submitted to the Department and inspections conducted by the Department.

WASTEWATER CHARACTERIZATION

The proposed wastewater discharge is characterized for the following regulated parameters:

Table 1: Wastewater Characterization

Parameter	Concentration
Total Organic Carbon, mg/L	1.7
Total Suspended Solids, mg/L	16
Temperature, ° C	10 ° C over river.
pH, SU	6.8 to 7.2

FACT SHEET FOR NPDES PERMIT NO. WA0000353

SEPA COMPLIANCE

This is an existing facility. Nevertheless, the facility completed a SEPA application which showed no significant issues.

PROPOSED PERMIT LIMITATIONS

Federal and state regulations require that effluent limitations set forth in a NPDES permit must be either technology- or water quality-based. Technology-based limitations are based upon the treatment methods available to treat specific pollutants. Technology-based limitations are set by regulation or developed on a case-by-case basis (40 CFR 125.3, and Chapter 173-220 WAC). Water quality-based limitations are based upon compliance with the Surface Water Quality Standards (Chapter 173-201A WAC), Ground Water Standards (Chapter 173-200 WAC), Sediment Quality Standards (Chapter 173-204 WAC) or the National Toxics Rule (Federal Register, Volume 57, No. 246, Tuesday, December 22, 1992). The more stringent of these two limits must be chosen for each of the parameters of concern. Each of these types of limits is described in more detail below.

The limits in this permit are based in part on information received in the application. The effluent constituents in the application were evaluated on a technology- and water quality-basis and the limits necessary to meet the rules and regulations of the state of Washington were determined and included in this permit. The Department does not develop effluent limits for all pollutants that may be reported on the application as present in the effluent. Some pollutants are not treatable at the concentrations reported and they are not controllable at the source and they don't have a reasonable potential to cause a water quality violation. If significant changes occur in any constituent, as described in 40 CFR 122.42(a), the Permittee is required to notify the Department.

DESIGN CRITERIA

In accordance with WAC 173-220-150 (1)(g), flows or waste loadings shall not exceed approved design criteria.

Table 2: Design Standards for the hydraulic capacity of the system.

Parameter	Design Quantity
Monthly average flow (max. month)	1.0 MGD
Instantaneous peak flow	1.5 MGD

FACT SHEET FOR NPDES PERMIT NO. WA0000353

TECHNOLOGY-BASED EFFLUENT LIMITATIONS

Since the production of zinc hydrosulfite ceased, the wastewater has been limited to non-contact cooling water. All other incidental process, washdown and rainwater has been collected and recycled as process water which leaves the site as product. There are no categorical limits for this process.

SURFACE WATER QUALITY-BASED EFFLUENT LIMITATIONS

In order to protect existing water quality and preserve the designated beneficial uses of Washington's surface waters, WAC 173-201A-060 states that waste discharge permits shall be conditioned such that the discharge will meet established Surface Water Quality Standards. The Washington State Surface Water Quality Standards (Chapter 173-201A WAC) is a state regulation designed to protect the beneficial uses of the surface waters of the state. Surface water quality-based effluent limitations may be based on an individual waste load allocation (WLA) or on a WLA developed during a basin wide total maximum daily loading study (TMDL).

NUMERICAL CRITERIA FOR THE PROTECTION OF AQUATIC LIFE

"Numerical" water quality criteria are numerical values set forth in the state of Washington's Water Quality Standards for Surface Waters (Chapter 173-201A WAC). They specify the levels of pollutants allowed in a receiving water while remaining protective of aquatic life. Numerical criteria set forth in the Water Quality Standards are used along with chemical and physical data for the wastewater and receiving water to derive the effluent limits in the discharge permit. When surface water quality-based limits are more stringent or potentially more stringent than technology-based limitations, they must be used in a permit.

NUMERICAL CRITERIA FOR THE PROTECTION OF HUMAN HEALTH

The U.S. EPA has promulgated 91 numeric water quality criteria for the protection of human health that are applicable to Washington state (EPA 1992). These criteria are designed to protect humans from cancer and other disease and are primarily applicable to fish and shellfish consumption and drinking water from surface waters.

NARRATIVE CRITERIA

In addition to numerical criteria, "narrative" water quality criteria (WAC 173-201A-030) limit toxic, radioactive, or deleterious material concentrations below those which have the potential to adversely affect characteristic water uses, cause acute or chronic toxicity to biota, impair aesthetic values, or adversely affect human health. Narrative criteria protect the specific beneficial uses of all fresh (WAC 173-201A-130) and marine (WAC 173-201A-140) waters in the state of Washington.

ANTIDEGRADATION

The state of Washington's Antidegradation Policy requires that discharges into a receiving water shall not further degrade the existing water quality of the water body. In cases where the natural conditions of a receiving water are of lower quality than the criteria assigned, the natural conditions shall constitute the water quality criteria. Similarly, when the natural conditions of a receiving water are of higher quality than the criteria assigned, the natural conditions shall constitute the water quality criteria. More information on the state Antidegradation Policy can be obtained by referring to WAC 173-201A-070.

The Department has reviewed existing records and is unable to determine if ambient water quality is either higher or lower than the designated classification criteria given in Chapter 173-201A WAC;

FACT SHEET FOR NPDES PERMIT NO. WA0000353

therefore, the Department will use the designated classification criteria for this water body in the proposed permit. The discharges authorized by this proposed permit should not cause a loss of beneficial uses.

CRITICAL CONDITIONS

Surface water quality-based limits are derived for the waterbody's critical condition, which represents the receiving water and waste discharge condition with the highest potential for adverse impact on the aquatic biota, human health, and existing or characteristic water body uses.

MIXING ZONES

The Water Quality Standards allow the Department to authorize mixing zones around a point of discharge in establishing surface water quality-based effluent limits. Both "acute" and "chronic" mixing zones may be authorized for pollutants that can have a toxic effect on the aquatic environment near the point of discharge. The concentration of pollutants at the boundary of these mixing zones may not exceed the numerical criteria for that type of zone. Mixing zones can only be authorized for discharges that are receiving all known, available, and reasonable methods of prevention, control and treatment (AKART) and in accordance with other mixing zone requirements of WAC 173-201A-100.

The National Toxics Rule (EPA, 1992) allows the chronic mixing zone to be used to meet human health criteria.

DESCRIPTION OF THE RECEIVING WATER

The facility discharges to the Columbia River which is designated as a Class A receiving water in the vicinity of the outfall. Other nearby point source outfalls include Pyramid Brewery and the proposed BHP Steel Mill. Characteristic uses include the following:

water supply (domestic, industrial, agricultural); stock watering; fish migration; fish rearing, spawning and harvesting; wildlife habitat; primary contact recreation; sport fishing; boating and aesthetic enjoyment; commerce and navigation. Water quality of this class shall meet or exceed the requirements for all or substantially all uses.

SURFACE WATER QUALITY CRITERIA

Applicable criteria are defined in Chapter 173-201A WAC for aquatic biota. In addition, U.S. EPA has promulgated human health criteria for toxic pollutants (EPA 1992). Criteria for this discharge are summarized below:

Fecal Coliforms	200 organisms/100 mL maximum geometric mean
Dissolved Oxygen	8.0 mg/L minimum
Temperature	20 degrees Celsius maximum or incremental increases above background
pH	6.5 to 8.5 standard units
Turbidity	less than 5 NTU above background
Toxics	No toxics in toxic amounts (see Appendix C for numeric criteria for toxics of concern for this discharge)

FACT SHEET FOR NPDES PERMIT NO. WA0000353

CONSIDERATION OF SURFACE WATER QUALITY-BASED LIMITS FOR NUMERIC CRITERIA

The derivation of surface water quality-based limits also takes into account the variability of the pollutant concentrations in both the effluent and the receiving water.

Under critical conditions there was no prediction of a violation of the temperature and pH criteria for the receiving water. Effluent limits for pH of 6.0 to 9.0 was found to be protective of the temperature and pH criteria and therefore was imposed instead of the technology-based limitation.

The mixing zone study which accompanied the permit application showed that the critical ambient temperature of the river is 22 degrees Celsius. The temperature of the effluent has been characterized as 10 degrees Celsius above ambient. The mixing zone calculation showed that the dilution of the effluent would raise the ambient temperature 0.037 degrees Celsius. Since the allowable rise above ambient is 0.3 degrees Celsius, an effluent temperature of 32.2 degrees Celsius would presumably result in an edge of mixing zone temperature of 22.237 degrees Celsius, within the regulation.

Toxic Pollutants--Federal regulations (40 CFR 122.44) require NPDES permits to contain effluent limits for toxic chemicals in an effluent whenever there is a reasonable potential for those chemicals to exceed the surface water quality criteria. This process occurs concurrently with the derivation of technology-based effluent limits. Facilities with technology-based effluent limits defined in regulation are not exempted from meeting the Water Quality Standards for Surface Waters or from having surface water quality-based effluent limits.

WHOLE EFFLUENT TOXICITY

The Water Quality Standards for Surface Waters require that the effluent not cause toxic effects in the receiving waters. Many toxic pollutants cannot be detected by commonly available detection methods. However, toxicity can be measured directly by exposing living organisms to the wastewater in laboratory tests and measuring the response of the organisms. Toxicity tests measure the aggregate toxicity of the whole effluent, and therefore this approach is called whole effluent toxicity (WET) testing.

Toxicity caused by unidentified pollutants is not expected in the effluent from this discharge as determined by the screening criteria given in Chapter 173-205 WAC. Therefore, no whole effluent toxicity testing is required in this permit. The Department may require effluent toxicity testing in the future if it receives information that toxicity may be present in this effluent.

HUMAN HEALTH

Washington's water quality standards now include 91 numeric health-based criteria that must be considered in NPDES permits. These criteria were promulgated for the state by the U.S. EPA in its National Toxics Rule (Federal Register, Volume 57, No. 246, Tuesday, December 22, 1992).

The Department has determined that the applicant's discharge is unlikely to contain chemicals regulated for human health.

SEDIMENT QUALITY

The Department has promulgated aquatic sediment standards (Chapter 173-204 WAC) to protect aquatic biota and human health. These standards state that the Department may require Permittees to evaluate the potential for the discharge to cause a violation of applicable standards (WAC 173-204-400).

The Department has determined through a review of the discharger characteristics and effluent characteristics that this discharge has no reasonable potential to violate the Sediment Management Standards.

FACT SHEET FOR NPDES PERMIT NO. WA0000353

GROUND WATER QUALITY LIMITATIONS

The Department has promulgated Ground Water Quality Standards (Chapter 173-200 WAC) to protect beneficial uses of ground water. Permits issued by the Department shall be conditioned in such a manner so as not to allow violations of those standards (WAC 173-200-100).

This Permittee has no discharge to ground and therefore no limitations are required based on potential effects to ground water.

COMPARISON OF EFFLUENT PERMIT LIMITS WITH THE EXISTING PERMIT ISSUED

Existing Limits	Proposed Limits
Flow, MGD, 1.0	No limit, report only
Temperature, 18° C	22.3° C at edge of mixing zone, 32.2° C at monitoring point
pH, range 6.5 to 9.0	pH 6.0 to 9.0
Note that the existing permit limits for zinc hydrosulfite have been eliminated with the production of this product	

MONITORING REQUIREMENTS

Monitoring, recording, and reporting are required (WAC 173-220-210 and 40 CFR 122.41) to verify that the treatment process is functioning correctly and the effluent limitations are being achieved.

The monitoring schedule is detailed in the proposed permit under Condition S.2. Specified monitoring frequencies take into account the quantity and variability of the discharge, the treatment method, past compliance, significance of pollutants, and cost of monitoring.

LAB ACCREDITATION

With the exception of certain parameters the permit requires all monitoring data to be prepared by a laboratory registered or accredited under the provisions of Chapter 173-50 WAC, *Accreditation of Environmental Laboratories*.

OTHER PERMIT CONDITIONS

REPORTING AND RECORDKEEPING

The conditions of S3. are based on the authority to specify any appropriate reporting and recordkeeping requirements to prevent and control waste discharges (WAC 273-220-210).

SPILL PLAN

The Department has determined that the Permittee stores a quantity of chemicals that have the potential to cause water pollution if accidentally released. The Department has the authority to require the Permittee to develop best management plans to prevent this accidental release under section 402(a)(1) of the Federal Water Pollution Control Act (FWPCA) and RCW 90.48.080.

The proposed permit requires the Permittee to develop and implement a plan for preventing the accidental release of pollutants to state waters and for minimizing damages if such a spill occurs.

GENERAL CONDITIONS

General Conditions are based directly on state and federal law and regulations and have been standardized for all individual industrial NPDES permits issued by the Department.

Condition G1 requires responsible officials or their designated representatives to sign submittals to the Department. Condition G2 requires the Permittee to allow the Department to access the treatment system, production facility, and records related to the permit. Condition G3 specifies conditions for modifying, suspending or terminating the permit. Condition G4 requires the Permittee to apply to the Department prior to increasing or varying the discharge from the levels stated in the permit application. Condition G5 requires the Permittee to construct, modify, and operate the permitted facility in accordance with approved engineering documents. Condition G6 prohibits the Permittee from using the permit as a basis for violating any laws, statutes or regulations. Conditions G7 and G8 relate to permit renewal and transfer. Condition G9 requires the Permittee to control its production in order to maintain compliance with its permit. Condition G10 prohibits the reintroduction of removed substances back into the effluent. Condition G11 states that the Department will modify or revoke and reissue the permit to conform to more stringent toxic effluent standards or prohibitions. Condition G12 incorporates by reference all other requirements of 40 CFR 122.41 and 122.42. Condition G13 notifies the Permittee that additional monitoring requirements may be established by the Department. Condition G14 requires the payment of permit fees. Condition G15 describes the penalties for violating permit conditions.

PERMIT ISSUANCE PROCEDURES

PERMIT MODIFICATIONS

The Department may modify this permit to impose numerical limitations, if necessary to meet Water Quality Standards for Surface Waters, Sediment Quality Standards, or Water Quality Standards for Ground Waters, based on new information obtained from sources such as inspections, effluent monitoring, outfall studies, and effluent mixing studies.

The Department may also modify this permit as a result of new or amended state or federal regulations.

FACT SHEET FOR NPDES PERMIT NO. WA0000353

RECOMMENDATION FOR PERMIT ISSUANCE

This proposed permit meets all statutory requirements for authorizing a wastewater discharge, including those limitations and conditions believed necessary to control toxics, protect human health, aquatic life, and the beneficial uses of waters of the state of Washington. The Department proposes that this proposed permit be issued for the period until June 30, 2002.

REFERENCES FOR TEXT AND APPENDICES

Environmental Protection Agency (EPA)

1992. National Toxics Rule. Federal Register, V. 57, No. 246, Tuesday, December 22, 1992.

1991. Technical Support Document for Water Quality-based Toxics Control. EPA/505/2-90-001.

1988. Technical Guidance on Supplementary Stream Design Conditions for Steady State Modeling. USEPA Office of Water, Washington, D.C.

1985. Water Quality Assessment: A Screening Procedure for Toxic and Conventional Pollutants in Surface and Ground Water. EPA/600/6-85/002a.

1983. Water Quality Standards Handbook. USEPA Office of Water, Washington, D.C.

Tsivoglou, E.C., and J.R. Wallace.

1972. Characterization of Stream Reaeration Capacity. EPA-R3-72-012. (Cited in EPA 1985 op.cit.)

Washington State Department of Ecology.

1994. Permit Writer's Manual. Publication Number 92-109

Wright, R.M., and A.J. McDonnell.

1979. In-stream Deoxygenation Rate Prediction. Journal Environmental Engineering Division, ASCE. 105(E2). (Cited in EPA 1985 op.cit.)

FACT SHEET FOR NPDES PERMIT NO. WA0000353

APPENDIX A--PUBLIC INVOLVEMENT INFORMATION

The Department has tentatively determined to reissue a permit to the applicant listed on page 1 of this fact sheet. The permit contains conditions and effluent limitations which are described in the rest of this fact sheet.

Public notice of application was published on August 20, 1997, in *The Daily News* to inform the public that an application had been submitted and to invite comment on the reissuance of this permit.

The Department will publish a Public Notice of Draft (PNOD) on November 12, 1997, in *The Daily News* to inform the public that a draft permit and fact sheet are available for review. Interested persons are invited to submit written comments regarding the draft permit. The draft permit, fact sheet, and related documents are available for inspection and copying between the hours of 8:00 a.m. and 5:00 p.m. weekdays, by appointment, at the regional office listed below. Written comments should be mailed to:

Water Quality Permit Coordinator
Department of Ecology
Southwest Regional Office
P.O. Box 47775
Olympia, WA 98504-7775

Any interested party may comment on the draft permit or request a public hearing on this draft permit within the thirty (30) day comment period to the address above. The request for a hearing shall indicate the interest of the party and reasons why the hearing is warranted. The Department will hold a hearing if it determines there is a significant public interest in the draft permit (WAC 173-220-090). Public notice regarding any hearing will be circulated at least thirty (30) days in advance of the hearing. People expressing an interest in this permit will be mailed an individual notice of hearing (WAC 173-220-100).

The Department will consider all comments received within thirty (30) days from the date of public notice of draft indicated above, in formulating a final determination to issue, revise, or deny the permit. The Department's response to all significant comments is available upon request and will be mailed directly to people expressing an interest in this permit.

Further information may be obtained from the Department by telephone, (360) 407-6285, or by writing to the address listed above.

This permit and fact sheet were written by Gary Anderson.

APPENDIX B--GLOSSARY

Acute Toxicity--The lethal effect of a compound on an organism that occurs in a short period of time, usually 48 to 96 hours.

AKART-- An acronym for "all known, available, and reasonable methods of treatment".

Ambient Water Quality--The existing environmental condition of the water in a receiving water body.

Ammonia--Ammonia is produced by the breakdown of nitrogenous materials in wastewater. Ammonia is toxic to aquatic organisms, exerts an oxygen demand, and contributes to eutrophication. It also increases the amount of chlorine needed to disinfect wastewater.

Average Monthly Discharge Limitation --The average of the measured values obtained over a calendar month's time.

Best Management Practices (BMPs)--Schedules of activities, prohibitions of practices, maintenance procedures, and other physical, structural and/or managerial practices to prevent or reduce the pollution of waters of the state. BMPs include treatment systems, operating procedures, and practices to control: plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage. BMPs may be further categorized as operational, source control, erosion and sediment control, and treatment BMPs.

BOD₅--Determining the Biochemical Oxygen Demand of an effluent is an indirect way of measuring the quantity of organic material present in an effluent that is utilized by bacteria. The BOD₅ is used in modeling to measure the reduction of dissolved oxygen in a receiving water after effluent is discharged. Stress caused by reduced dissolved oxygen levels makes organisms less competitive and less able to sustain their species in the aquatic environment. Although BOD is not a specific compound, it is defined as a conventional pollutant under the federal Clean Water Act.

Bypass--The intentional diversion of waste streams from any portion of a treatment facility.

Chlorine--Chlorine is used to disinfect wastewaters of pathogens harmful to human health. It is also extremely toxic to aquatic life.

Chronic Toxicity--The effect of a compound on an organism over a relatively long time, often 1/10 of an organism's lifespan or more. Chronic toxicity can measure survival, reproduction or growth rates, or other parameters to measure the toxic effects of a compound or combination of compounds.

Clean Water Act (CWA)--The Federal Water Pollution Control Act enacted by Public Law 92-500, as amended by Public Laws 95-217, 95-576, 96-483, 97-117; USC 1251 et seq.

Compliance Inspection - Without Sampling--A site visit for the purpose of determining the compliance of a facility with the terms and conditions of its permit or with applicable statutes and regulations.

Compliance Inspection - With Sampling--A site visit to accomplish the purpose of a Compliance Inspection - Without Sampling and as a minimum, sampling and analysis for all parameters with limits in the permit to ascertain compliance with those limits; and, for municipal facilities, sampling of influent to ascertain compliance with the 85 percent removal requirement. Additional sampling may be conducted.

Composite Sample--A mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing discrete samples. May be "time-composite"(collected at constant time intervals) or "flow-proportional" (collected either as a constant sample volume at time intervals proportional to stream flow, or collected by increasing the volume of each aliquot as the flow increased while maintaining a constant time interval between the aliquots.

FACT SHEET FOR NPDES PERMIT NO. WA0000353

Construction Activity--Clearing, grading, excavation and any other activity which disturbs the surface of the land. Such activities may include road building, construction of residential houses, office buildings, or industrial buildings, and demolition activity.

Critical Condition--The time during which the combination of receiving water and waste discharge conditions have the highest potential for causing toxicity in the receiving water environment. This situation usually occurs when the flow within a water body is low, thus, its ability to dilute effluent is reduced.

Dilution Factor--A measure of the amount of mixing of effluent and receiving water that occurs at the boundary of the mixing zone. Expressed as the inverse of the percent effluent fraction e.g., a dilution factor of 10 means the effluent comprises 10% by volume and the receiving water 90%.

Engineering Report--A document which thoroughly examines the engineering and administrative aspects of a particular domestic or industrial wastewater facility. The report shall contain the appropriate information required in WAC 173-240-060 or 173-240-130.

Fecal Coliform Bacteria--Fecal coliform bacteria are used as indicators of pathogenic bacteria in the effluent that are harmful to humans. Pathogenic bacteria in wastewater discharges are controlled by disinfecting the wastewater. The presence of high numbers of fecal coliform bacteria in a water body can indicate the recent release of untreated wastewater and/or the presence of animal feces.

Grab Sample--A single sample or measurement taken at a specific time or over as short period of time as is feasible.

Industrial Wastewater--Water or liquid-carried waste from industrial or commercial processes, as distinct from domestic wastewater. These wastes may result from any process or activity of industry, manufacture, trade or business, from the development of any natural resource, or from animal operations such as feed lots, poultry houses, or dairies. The term includes contaminated storm water and, also, leachate from solid waste facilities.

Major Facility--A facility discharging to surface water with an EPA rating score of > 80 points based on such factors as flow volume, toxic pollutant potential, and public health impact.

Maximum Daily Discharge Limitation--The highest allowable daily discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. The daily discharge is calculated as the average measurement of the pollutant over the day.

Method Detection Level (MDL)--The minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is above zero and is determined from analysis of a sample in a given matrix containing the analyte.

Minor Facility--A facility discharging to surface water with an EPA rating score of < 80 points based on such factors as flow volume, toxic pollutant potential, and public health impact.

Mixing Zone--An area that surrounds an effluent discharge within which water quality criteria may be exceeded. The area of the authorized mixing zone is specified in a facility's permit and follows procedures outlined in state regulations (Chapter 173-201A WAC).

National Pollutant Discharge Elimination System (NPDES)--The NPDES (Section 402 of the Clean Water Act) is the federal wastewater permitting system for discharges to navigable waters of the United States. Many states, including the state of Washington, have been delegated the authority to issue these permits. NPDES permits issued by Washington state permit writers are joint NPDES/State permits issued under both state and federal laws.

pH--The pH of a liquid measures its acidity or alkalinity. A pH of 7 is defined as neutral, and large variations above or below this value are considered harmful to most aquatic life.

FACT SHEET FOR NPDES PERMIT NO. WA0000353

Quantitation Level (QL)-- A calculated value five times the MDL (method detection level).

Technology-based Effluent Limit--A permit limit that is based on the ability of a treatment method to reduce the pollutant.

Total Suspended Solids (TSS)--Total suspended solids is the particulate material in an effluent. Large quantities of TSS discharged to a receiving water may result in solids accumulation. Apart from any toxic effects attributable to substances leached out by water, suspended solids may kill fish, shellfish, and other aquatic organisms by causing abrasive injuries and by clogging the gills and respiratory passages of various aquatic fauna. Indirectly, suspended solids can screen out light and can promote and maintain the development of noxious conditions through oxygen depletion.

State Waters--Lakes, rivers, ponds, streams, inland waters, underground waters, salt waters, and all other surface waters and watercourses within the jurisdiction of the state of Washington.

Stormwater--That portion of precipitation that does not naturally percolate into the ground or evaporate, but flows via overland flow, interflow, pipes, and other features of a storm water drainage system into a defined surface water body, or a constructed infiltration facility.

Upset--An exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventative maintenance, or careless or improper operation.

Water Quality-based Effluent Limit--A limit on the concentration of an effluent parameter that is intended to prevent the concentration of that parameter from exceeding its water quality criterion after it is discharged into a receiving water.

APPENDIX C--TECHNICAL CALCULATIONS

Several of the Excel[®] spreadsheet tools used to evaluate a discharger's ability to meet Washington state water quality standards can be found on the Department's homepage at <http://www.wa.gov/ecology>.

APPENDIX D--RESPONSE TO COMMENTS